

November 13, 2019
Addendum #4
IFB/RFQ# 2019-001

41st Street Building CDBG Capital Projects

Clarification for Roof Replacement

1. TPO single-ply roofing membrane is to be applied/installed over flat roof area, only.
2. Pitched areas are to be replaced with like-material (two-layers shingle).